



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Allen County
Indian Village Mobile Home Park
Community Water System
PWS ID. NO: 0200712

October 2, 2008

Mr. Trace Meyer
Park Management Specialist
216 West Wayne Street
Maumee, Ohio 43537-2125

OH0200712

INDIAN VILLAGE MOBILE HOME PARK

10/2/2008



Dear Mr. Meyer:

The Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), has received and reviewed the Plant-Distribution Monthly Operating Report (EPA form 5002) for the month of August 2008.

Ohio Administrative Code (OAC) Rule 3745-83-01(G)(9)(B) states that, "A public water system serving two hundred and fifty or more persons that provides treatment to reduce iron shall monitor for iron at least weekly at each entry point into the distribution system using a state certified laboratory. A public water system serving two hundred and fifty or more persons may reduce the frequency of certified laboratory analyses for iron to no less than once each month provided the following conditions are met: (i) The public water system monitors once every day that water is available to the public for iron using an in-house test kit at each entry point into the distribution system. The test kit shall have a minimum detection level of 0.2 milligrams per liter for iron; and (ii) The public water system has one split sample analyzed monthly by an in-house test kit and by a certified laboratory. The deviation between results shall be no greater than 0.2 milligrams per liter for iron. If the split sample results for iron vary by more than 0.2 milligrams per liter, the public water system shall resume weekly monitoring using a certified laboratory. A public water system may return to a reduced frequency of certified laboratory analyses for iron once the deviation of split sample results is within the accepted limits specified in this paragraph."

Iron sampling must be completed at the entry point on a weekly basis at the Indian Village Mobile Home Park. A reduced frequency of monitoring can be completed if the above conditions are met. There are no monitoring results for iron documented in the August 2008 monthly report.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters
/csl

cc: Danielle Mistyurik, Indian Village MHP
Shawn Daley, UnitTech
Allen County Health Department
DDAGW, NWDO File