



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Indian Village Mobile Home Park
Community Water System
PWS ID. NO: 0200712

September 24, 2008

OH0200712

INDIAN VILLAGE MOBILE HOME PARK

9/24/2008

Mr. Trace Meyer
Park Management Specialist
216 West Wayne Street
Maumee, Ohio 43537-2125



Re: 2007 Consumer Confidence Report

Dear Mr. Meyer:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2006 Consumer Confidence Report (CCR) for Indian Village Mobile Home Park on July 28, 2008. The CCR was reviewed for the required content. Based on our review, the Indian Village Mobile Home Park water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. A copy of the consumer confidence report and the certification were not received by Ohio EPA by July 1, 2008.
2. The Table of Detected Contaminants contained incorrect information. The 2005 90th percentile detected level for copper should be reported as 169.5 ug/L. Lead was below detection for all samples and should not be included in the table. The TTHM and HAA5 levels are below the reporting limit and do not need to be reported in the table. The level found for total chlorine should have been reported as 1.11.
3. The source water susceptibility language was not included in the report.

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website: www.epa.state.oh.us/ddagw.

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Danielle Mistyurik, Indian Village MHP
Allen County Health Department
DDAGW, NWDO File