



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Sun Valley Family Campground
Community Water System
PWS ID# 0252212

February 22, 2007

OH0252212

SUN VALLEY FAMILY CAMPGROUND

2/22/2007

Mr. Richard L. Williams, Owner
Sun Valley Family Campground
9180 Parker Road
Harrod, Ohio 45850



Dear Mr. Williams:

The Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), has received and reviewed the Plant-Distribution Monthly Operating Report (EPA form 5002) for the month of January 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01(G)(9)(a) states that, "A public water system serving fewer than two hundred and fifty persons that provides treatment to reduce iron shall monitor for iron at least monthly at each entry point into the distribution system using state certified laboratory."

OAC Rule 3745-83-01(G)(8)(a) states that, "A public water system serving fewer than two hundred and fifty persons that provide ion exchange treatment or membrane technology to reduce hardness shall monitor for hardness at least monthly at each entry point to the distribution system using a state certified laboratory."

In addition to reporting the daily plant production and chlorine residual sampling completed, Sun Valley Family Campground must also report monthly iron and hardness levels. The iron and hardness monthly samples must be analyzed at a state certified laboratory.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: James Williams, Sun Valley Family Campground
Seneca County Health Department

~~DDAGW; NWDO File~~