



State of Ohio Environ OH0300312

BAILEY LAKES VILLAGE

9/24/2008

Northwest

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8
www.ohio.gov



* 0 H 0 3 0 3 1 2 9 2 4 2 0 0 8 N O V *

VILLAGE MANAGER, DIRECTOR

Re: Ashland County
Village of Bailey Lakes
Community Water System
PWS ID. NO: 0300312

September 24, 2008

The Honorable Kenneth Carpenter
Mayor of the Village of Bailey Lakes
760 Lake Drive
Ashland, Ohio 44805

Re: 2007 Consumer Confidence Report

Dear Mayor Carpenter:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for the Village of Bailey Lakes on June 27, 2008. The CCR was reviewed for the required content. Based on our review, the Village of Bailey Lakes water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants did not contain required information. The level found and range of detection were reported incorrectly for Total Trihalomethane (TTHM) and Five Haloacetic Acids (HAA5). The highest running annual average must be reported in the level found (TTHM=47.6 and HAA5=30.1) and the range will report the lowest to the highest numbers for all four quarters used to calculate the running annual average (TTHM=23.5 to 63.6 and HAA5=14.5 to 43.5). The highest running annual average for total chlorine must be reported for the level found (1.37). Statements that specify that 0 of 5 samples exceeded the action level for lead and copper must be included in the report.

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website: www.epa.state.oh.us/ddagw.

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Ottawa County Health Department
Tim Hickey, Operator
«DDAGW; NWDO File»