



State of Ohio Environmental Protection Agency

Northwest

OH0300512

GREEN ACRES MHP

2/19/2010

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-84
www.epa



Re: Ashland County
Green Acres MHP
Community Water System
PWS ID# OH0300512

February 19, 2010

Ms. Lois Welsch
Green Acres MHP
1346 State Route 89
Ashland, Ohio 44805

Dear Ms. Welsch:


Ohio Administrative Code (OAC), Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your December 2009 and your January 2010 operational reports indicate that free chlorine residuals were below this level a total of 31 days in December 2009 and 31 Days in January 2010.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly,


Curtis Eldridge
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Ashland County Health Department
DDAGW, NWDO, File