



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ashland County
Hidden Acres MHP
Community Water System
PWS ID# OH0300812

June 8, 2010

OH0300812

HIDDEN ACRES MHP

6/8/2010

Mr. James Kovacich
Hidden Acres MHP
107 Township Road 810; Lot 40
West Salem, Ohio 44287



Dear Mr. Kovacich:

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your April 2010 operational reports indicate that free chlorine residuals were below this level a total of 18 days in April 2010.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly,

Curtis A. Eldridge
Environmental Specialist 2
Division of Drinking and Ground Water

/cs

pc: Ashland County Health Department
CDBAGW;NWDO File

