



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ashland County  
Hidden Acres MHP  
Community Water System  
PWS ID# OH0300812

February 19, 2010

OH0300812

HIDDEN ACRES MHP

2/19/2010

Mr. James Whittlesey  
Hidden Acres MHP  
107 Township Road 810; Lot #40  
West Salem, Ohio 44287



Dear Mr. Whittlesey:

Ohio Administrative Code (OAC), Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your December 2009 and your January 2010 operational reports indicate that free chlorine residuals were below this level a total of 10 days in December 2009 and 16 days in January 2010.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at [curt.eldridge@epa.state.oh.us](mailto:curt.eldridge@epa.state.oh.us).

Yours truly,

Curtis Eldridge  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/cs

pc: Ashland County Health Department  
~~DDAGW-NWDO.File~~

