



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director


Re: Ashland County  
Hidden Acres MHP  
Community Water System  
PWS ID# 0300812

OH0300812

HIDDEN ACRES MHP

11/27/2007

November 27, 2007



Mr. James Kovacich  
Hidden Acres Mobile Home Park  
107 TR 810 Lot 40  
West Salem, Ohio 44287

Dear Mr. Kovacich:

Ohio Administrative Code, Rule 3745-83-01(G)(1) and (2) requires that each community and non-transient non-community water system that provides water treated with chlorine to monitor for free and combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point in the distribution system.

Review of your operational reports indicates that free/combined chlorine residuals were not reported at the entry point to the distribution system. Please begin reporting these residuals upon receipt of this letter.

If you have any questions, contact me at (419) 373-4117.

Yours truly,

Linda Benham  
Division of Drinking and Ground Waters

/lb

pc: Ashland County Health Department

~~DDAGW, NWDO~~