



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ashland County  
Village of Jeromesville  
Community Water System  
PWS ID. NO: 0300912

September 24, 2008

OH0300912

JEROMESVILLE VILLAGE

9/24/2008

Mr. Paul Lapp  
Village of Jeromesville  
26 South Street  
P.O. Box 83  
Jeromesville, Ohio 44840



**Re: 2007 Consumer Confidence Report**

Dear Mr. Lapp:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for the Village of Jeromesville on June 10, 2008. The CCR was reviewed for the required content. Based on our review, the Village of Jeromesville water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants did not contain required information. The 2005 detections of Bromoform, Bromodichloromethane, and Chlorodibromomethane should have been reported in the table of detected contaminants. (2008 sampling results cannot be applied to the report for the 2007 reporting year)

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website:  
[www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw) .

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lir

pc: Ottawa County Health Department  
Holly McGhee, Operator  
DDAGW, NWDO File