




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH0301312

MOHICAN RIVER ESTATES

9/13/2011



Re: Ashland County  
Mohican River Estates  
COMM Public Water System  
PWS # OH0301312

September 13, 2011

Ms. Julie Vantaggi  
Mohican River Estates  
6 Corporation Center  
Broadview Heights, Ohio 44147

### Notice of Violation – Monthly Report

Dear Ms. Vantaggi:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. The secondary standard for manganese was exceeded during the months of May, June and July 2011.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.


Violation of the secondary standard for manganese does not require public notification. Please review your operations to **determine the reason for the continued exceedance and advise this office as to what specific corrections** will be made.

Mohican River Estates must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. Your response to this letter is required by October 31, 2011.

Ms. Julie Vantaggi  
September 13, 2011  
Page 2

If you have any questions, please contact me at 419-373-3107 or  
Elizabeth.ames@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Elizabeth Ames", with a long horizontal flourish extending to the right.

Elizabeth Ames  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lr

pc: Janet Makeever  
Ashland County Health Department  
DDAGW-NWDO File ;