




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH0301312

MOHICAN RIVER ESTATES

6/1/2011



Re: Ashland County
Mohican River Estates
Community Public Water System
PWS # OH0301312

June 1, 2011

Ms. Julie Vantaggi
Mohican River Estates
6 Corporation Center
Broadview Heights, Ohio 44147

Notice of Violation – Monthly Report

Dear Ms Vantaggi:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. The secondary standard for manganese was exceeded during the months of January and April 2011.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01(F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mohican River Estates must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. Your response to this letter is required by June 30, 2011.

If you have any questions, please contact me at 419-373-3107 or elizabeth.ames@epa.state.oh.us.

Sincerely,

Elizabeth Ames
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Janet Makeever
Ashland County Health Department
DDAGW-NWDO-File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov