



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ashland County
Mohican River Estates
Community Water System
PWS ID. NO: 0301312

September 24, 2008

OH0301312

MOHICAN RIVER ESTATES

9/24/2008

Mr. Daniel Inks, Manager
Mohican River Estates
9 Corporation Center
Broadview Heights, Ohio 44147



Re: 2007 Consumer Confidence Report

Dear Mr. Inks:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for Mohican River Estates on June 27, 2008. The CCR was reviewed for the required content. Based on our review, the Mohican River Estates water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants did not contain required information. The 2005 detections of Bromoform, Bromodichloromethane, and Chlorodibromomethane should have been reported in the table of detected contaminants. Xylenes were non-detect and therefore should not be included in the table. The 90th percentile lead level found in 2005 should have been reported as 9.5 and a statement should have been included in the table noting that 1 of the 5 samples exceeded the action level for lead. The copper detection should include a statement noting that 0 of the 5 samples exceeded the action level for copper. Lastly, the range of detections for total chlorine should be the lowest to highest monthly levels (0.35 to 1.3).
2. As documented on the certification form it appears a good faith effort to reach all non-bill paying consumers was not made.

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website: www.epa.state.oh.us/ddagw.

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

//

pc: Ottawa County Health Department

DDAGW, NWDO File