



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Auglaize County  
Village of Cridersville  
Community Water System  
PWS ID#OH0600212

June 24, 2008

OH0600212

CRIDERSVILLE VILLAGE WATER

6/24/2008

Mr. John McDonald, Village Administrator  
Village of Cridersville  
110 West Main Street  
Cridersville, Oh 45806



Subject: 2007 CCR

Dear Mr. McDonald:

Ohio EPA received the 2007 Consumer Confidence Report (CCR) for the Village of Cridersville on June 18, 2008. The CCR was reviewed for the required content. Based on our review, the Village of Cridersville PWS is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-02 for the following omissions:

1. Definition of Maximum Residual Disinfectant Level (MRDL) was omitted.
2. The table of detected contaminants reported as a group (HAA5s) rather than individual contaminants detected in a sample collected from the entry point. The following individual detected contaminants should be included in the table of detected contaminants.
  - a. Dibromoacetic Acid 3.24 ug/l                      Sample date: 10/23/03
  - b. Dichloroacetic Acid 1.33 ug/l                      Sample date: 10/23/03

Note: The Table is to include the most recent data for detected contaminants but does not need to include any data older than five years. Contaminants detected in 2003 may be omitted from the consumer confidence report for calendar year 2008.

Be sure to correct the violations as appropriate in your next CCR. The next Consumer Confidence Report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Northwest District Office at the above address. The CCR template and template guide are accessible on our website: [www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw).

If you have any questions, please contact me at 419-373-3042.

Sincerely,

Larry W. Moritz, R.S., M.S.I.H.  
Division of Drinking and Ground Waters  
/lb

pc: Auglaize County Health Department

~~DDAGW/NWDO~~