



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH0600312

LAKESIDE ESTATES MOBILE HOME PARK

5/19/2011



Re: Auglaize County  
Community PWS  
Lakeside Estates MHP  
PWS ID# OH0600312  
STU ID# 652911

May 19, 2011

Certified Mail 7009 1410 0001 1840 1829

Mr. Robert Reck  
P. O. Box 95  
Bradford, Ohio 45308

Dear Mr. Reck:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Lakeside Estates MHP has not complied with requirements issued during this Agency's last survey performed on March 23, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code (OAC). You were notified in correspondence dated April 8, 2011, to respond in writing no later than 30 days, with time frames for:

- 1) OAC Rule 3745-81-70 states "Each public water system required to monitor under this rule shall develop and implement a monitoring plan. The public water system shall maintain the plan and make it available for inspection by the director and the general public." Update the Disinfectant/Disinfection Byproducts Sample Monitoring Plan by completing all sections applicable to your system. This plan was not available for review during the March 23, 2011, survey. A copy of this plan shall be submitted to this office for review.
- 2) OAC Rule 3745-7-09(A) states "The owner and operator of record of a public water system, treatment works or sewerage system shall maintain or cause to be maintained operation and maintenance records for each public water system." As of March 23, 2011, the operator of record was not maintaining an operational log that included the date and time of arrival and departure for the operator.
- 3) OAC Rule 3745-95-03(A) states "The supplier of water shall conduct or cause to be conducted periodic surveys and investigations, of frequency acceptable to the director, of water use practices within a consumer's premises to determine whether there are actual or potential cross-connections to the consumer's water system through which contaminants or pollutants could backflow into the public water system." As of March 23, 2011, a written plan or a record of implementation of that plan was not available.

Mr. Robert Reck  
May 19, 2011  
Page Two

- 4) OAC Rule 3745-9-05(P) states "Electrical conduit connections on the well cap or seal shall be threaded and sealed to prevent the entrance of insects and water." The electrical wires shall be put into conduit and sealed to the sanitary seal to prevent the entry or exit of insects or water. All materials used must meet NSF Standard 60/61.
- 5) OAC Rule 3745-85-01(C)(1) states "One copy of the contingency plan shall be kept at the water treatment plant, if there is a plant, and another shall be kept in the water system administrator's office." In addition, OAC Rule 3745-85-01(E)(1) states that, "The contingency plan...shall be revised and updated as necessary but at least annually." A copy of the contingency plan was not available for review during the survey. The onsite copy should be kept in a protected location to ensure it is available for use during an emergency.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, contact me at 419-373-3101.


Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/cs

pc: Auglaize County Health Department  
Central Office, DDAGW  
DDAGW, NWDO File

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY	
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	A. Signature  <input type="checkbox"/> Agent <input type="checkbox"/> Addressee	
	B. Received by (Printed Name)	C. Date of Delivery
1. Article Addressed to: <i>Mr. Robert Reck            Lakeide Estates MHP            P.O. Box 95            Bradford, Ohio            45308</i>	D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No	
	3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.	
	4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes	
	 <i>dpdw/cr</i>	
PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540		

U.S. Postal Service™ <i>dpdw/cr</i>	
CERTIFIED MAIL™ RECEIPT	
(Domestic Mail Only; No Insurance Coverage Provided)	
For delivery information visit our website at <a href="http://www.usps.com">www.usps.com</a>	
<i>Lakeide Estates</i> OFFICIAL USE	
Postage	\$ <i>.44</i>
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$ <i>5.59</i>
Sent to <i>Mr. Robert Reck</i>	
Street, Apt. No., or PO Box No. <i>P.O. Box 95</i>	
City, State, ZIP+4 <i>Bradford, Ohio 45308</i>	
PS Form 3800, August 2006 See Reverse for Instructions	

ROWLING GREEN OH 45308  
 MAY 19 2011  
 USPS  
 Mark Here

629T 1840 1829  
 700T 0001 1840 1829  
 0001 1840 1829