



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Auglaize County
Lakeside Estates MHP
Community PWS
PWS ID# OH0600312

August 15, 2007

OH0600312

LAKESIDE ESTATES MOBILE HOME PARK

8/15/2007

Robert and Jill Reck
P.O. Box 95
Bradford, Ohio 45308



Dear Mr. & Mrs. Reck:

Ohio Administrative Code (OAC) Rule 3745-83-01 (C)(1) requires that each community public water system maintain a minimum chlorine residual of at least two-tenths milligram per liter free chlorine, or one milligram per liter combined chlorine measured at representative points throughout the distribution system. Review of your July 2009 monthly operation report indicates that free/combined chlorine residuals were below this level five days during the month. Within 7 days, submitted a written response describing the action taken to address this deficiency.

OAC Rule 3745-83-01 (I) (2) requires the operation report to be signed by the operator in responsible charge designated in accordance with OAC Rule 3745-7-02 (Certified Operators Required). The certification number included on your report, 03-600312-56255, is not recognized as a valid certification for the operation of a public water system. The name of the certified operator was not printed nor was the signature legible. Within 7 days, submit a written response identifying the responsible person signing the monthly operation report and sponsor of the certification number.

Questions may be directed to my attention at 419-373-3042.

Sincerely,

Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

pc: Auglaize County Health Department

DDAGW/NWDO

ec: Ellen Gerber, Manager, DDAGW/NWDO\
Andrew Barienbrock, Operator Certification Unit, DDAGW/CO