



State of Ohio Enviror

OH1700011 BUCYRUS CITY

38 02/20/09

Northwest



TELE: (419) 352-  
www.e

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

Crawford County  
City of Bucyrus  
CWS  
PWS OH1700011

February 20, 2009

Don Fox  
City of Bucyrus  
500 S Sandusky Ave  
Bucyrus OH 44820-2623

Subject: Individual Filter Turbidity Monitoring Violation

Dear Mr. Fox:

In violation of rules 3745-81-74(B)(1 & 2), the public water system failed to record the results of individual filter turbidity monitoring every 15 minutes during 11 working days of January 29 through February 17, 2009.

On February 17, 2009, the continuous individual filter monitoring and recording every 15 minutes were returned to service.

If the public water system fails to correct its violations, then the director may enforce the safe drinking water rules to attain compliance. An enforcement action may include civil penalties of not more than \$25000 per day per violation in accordance with RC §§6109.33, or administrative penalties in accordance with rule 3745-81-04.

If you have any questions regarding this letter, or any other matter involving your water system, you may contact me at (419)373-3048, or email at [Ralph.Baker@epa.state.oh.us](mailto:Ralph.Baker@epa.state.oh.us).

Sincerely,

Ralph J. Baker  
Engineer  
Division of Drinking and Ground Waters  
/lb  
PC

EC Ralph Baker, DDAGW, NWDO  
Toni Buchanan, DDAGW, CO