



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Defiance County
Christi Water System Inc
Community Water System
PWS ID# OH2001003
STU ID# 2053837

January 11, 2011

OH2001003

CHRISTI WATER SYSTEM INC

1/11/2011

Mr. Terry Beilharz, President
Christi Water System, Inc.
200 Perry Street
Defiance, Ohio 43512



Re: Notice of Violation – Monthly Report

Dear Mr. Beilharz:

The November 2010, Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District office on December 8, 2010.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of November 2010, monthly report shows 21 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the plant tap and in distribution.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373- 3089 or via e-mail to jill.schiefer@epa.ohio.gov.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

//lr

pc: Defiance County Health Department
~~DDAGW-NWDO-File~~

ec: JoAnn Sabo, DOCC, NWDO
Rick Schantz, Operator of Record rischantz@rtexpress.net
Ellen Gerber, Manager, NWDO
Linda Benham, Supervisor, NWDO

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov