



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH2001003

CHRISTI WATER SYSTEM INC

9/14/2010



Re: Defiance County
Christi Water System, Inc.
Community Water System
PWS ID# OH2001003
STU ID# 2053837

September 14, 2010

Mr. Terry Beilharz, President
Christi Water System, Inc.
200 Perry Street
Defiance, Ohio 43512

Re: Notice of Violation – Monthly Report

The July 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District office on August 4, 2010.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of the July 2010 report shows 10 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the plant tap and in distribution.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373- 3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Defiance County Health Department
DDAGW;NWDO-File
ec: JoAnn Sabo, DOCC, NWDO
Rick Schantz, Operator of Record