



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Defiance County
Hicksville Village Water PWS
Community Public Water System
PWS ID# 2000212

March 10, 2011

OH2000212

HICKSVILLE VILLAGE WATER

10/10/2011

Mr. Thomas Horn, Operator of Record
Hicksville Village Water
2926 U. S. Route 6
McClure, Ohio 43534



**Notice of Violation – Monthly Report – Chlorine Residual Distribution
Notice of Deficiency – Monthly Report – Chlorine Residuals – Plant Tap**

Dear Mr. Horn:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system December 1, 2, 4, and 7.

OAC Rule 3745-83-01 (C) (1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.


Notice of Deficiency

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l on December 1, 7, and 13 at the plant tap. Investigate the cause of this deficiency and take measures to correct it.

Mr. Thomas Horn, Operator of Record
March 10, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Kent Miller
Defiance County Health Department
DAGW-NWDO File