




**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korieski, Director

OH2000212

HICKSVILLE VILLAGE WATER

11/23/2010



Re: Defiance County
Village of Hicksville
Community Water System
PWS ID# OH2000212
STU ID# 2053831

November 23, 2010

Mr. Kent Miller, Village Administrator
Village of Hicksville
111-113 South Main Street
Hicksville, Ohio 43526

Notice of Violation – Monthly Report

Dear Mr. Miller:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on 5 days in October 2010.

OAC Rule 3745-83-01(C)(1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Defiance County Health Department
~~DDAGW;NWDO;File~~