



State of Ohio Environmental Protection Agency


Northwest

OH2000212 HICKSVILLE VILLAGE WATER

22 06/03/10

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352
www



Re: Defiance County
Hicksville Village Water
Community Water System
PWS ID: OH2000212

June 4, 2010

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Kent Miller
Village of Hicksville
111-113 South Main Street
Hicksville, Ohio 43526

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During June 2010 (Monthly)**

Hicksville Village Water is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
06-01-10	225 East High St – Restroom Sink	Positive	Negative	--	8538	83
06-01-10	200 West High St – Wash Room Sink	Positive	Negative	--	8539	83

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Mail or other direct delivery to each customer;
 - If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved).


Mr. Kent Miller
June 4, 2010
Page 2

The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during the month of July 2010.

If you have any questions, contact this office at 419-373-3089.

Sincerely,



Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

pc: Defiance County Health Department
Information Management Section, DDAGW, CO
DDAGW-NWDO (w/enclosures)