




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH2201011 HURON WATER TREATMENT PLANT

22 07/18/11



Re: Erie County
Huron Water Treatment Plant
Community Water System
PWS ID: OH2201011

July 19, 2011

Mr. Andy White
Huron Water Treatment Plant
417 Main Street
Huron, Ohio 44839

NOTICE OF VIOLATION – ACTION REQUIRED

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During July 2011. (Monthly)**

Huron Water Treatment Plant is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:


- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Mail or other direct delivery to each customer;
 - If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

Mr. Andy White
July 19, 2011
Page 2

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 419-373-3103.

Sincerely,



Musa Khaleq, P.E.
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

pc: Erie County Health Department
Information Management Section, DDAGW, CO
DDAGW = NWDO (w/enclosures)