



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Fulton County
Village of Fayette
Community Water System
PWS ID# 2600412

April 22, 2008

OH2600412

FAYETTE VILLAGE

4/22/2008

Mr. Tom Speiss, Village Administrator
Village of Fayette
125 West Main Street
P. O. Box 87
Fayette, Ohio 43521



Subject: NOV for Failure to Submit Quarterly Operating Reports

Dear Mr. Speiss:

The Total Chlorine Residual Quarterly Operating Report (EPA 5114, revised April 2004) (QOR) for the second quarter of 2007, the third quarter of 2007 and the fourth quarter of 2007 for the Village of Fayette have not been received by our office.

Disinfection residual measurements are required to be taken for **total chlorine** according to Ohio Administrative Code, Rule 3745-81-70(E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [i.e., The second calendar quarter (April – June) should be submitted to the district office no later than July 10th.]

If you have any questions, please contact me at (419)373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: DDAGW; NWDO File }