



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Fulton County  
Swan Creek Water District #1  
Community Water System  
PWS ID# 2601412

February 16, 2007

OH2601412

SWANCREEK WATER DISTRICT 1

2/16/2007

Mr. Mark Fowler, President  
Swan Creek Township Board  
5565 County Road D  
Delta, Ohio 43515



**Notice of Violation: Failure to Maintain The Minimum Chlorine Residual**

Dear Mr. Fowler:

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Review of your operational reports for February indicates that free/combined chlorine residuals were below this level 8 days during this month.

Please take prompt action to correct these deficiencies in your public water supply. Continued inadequate disinfection residual violations in future reports may result in further enforcement action.

If you have any questions regarding this letter, please contact me at (419) 373-4117.

Yours truly,

Linda S. Benham  
Division of Drinking and Ground Waters

/csi

cc: Ms. Tina Whalen, District Manager  
Mr. Ziad Musallam, Technical Supervisor  
Fulton County Health Department  
NWDO DDAGW File