



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Fulton County
Swanton Meadows MHP
Community Water System
PWS ID# OH2601212

October 10, 2008

OH2601212

SWANTON MEADOWS

10/10/2008

Ms. Sandy Schiel, Regional Manager
MC Equities, LLC
990 Beach Avenue; Suite 114
Vancouver, British Columbia
V6Z 2N9
Canada



Subject: Violation for September 2008 Monthly Report

Dear Ms. Schiel:

Review of the monthly operational report for September 2008 indicates your water system is in violation of Ohio Administrative Code Rule 3745-83-01(l)(c) for failure to include the daily pumpage of the plant on the Ohio EPA Form 5002.

The daily water treatment system pumpage is to be reported on Ohio EPA Form 5002 and is to be corrected in the next monthly report (October 2008).

If you have any questions regarding this matter, I can be contacted at (419)373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: Mike Forche, Superintendent of Water
Fulton County Health Department
DDAGW, NWDO File
ec: Carol Snyder, Manager
Bill Geniella, AMHRO
Linda Benham, Supervisor, DDAGW, NWDO