



State of Ohio Envir

OH3200012

ARLINGTON VILLAGE WATER

12/18/2007

**Northwes**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352  
www



\* 0 H 3 2 0 0 0 1 2 1 2 1 8 2 0 0 7 N O V \*

Re: Hancock County  
Village of Arlington  
Community Water System  
PWS ID# 3200012

December 18, 2007

Mr. Paul Beidelschies, President  
Board of Public Affairs  
204 North Main Street  
Arlington, Ohio 45814

**Subject: CCR Violations for 2006 Reporting Year**

Dear Mr. Beidelschies:

Ohio EPA received the 2006 Consumer Confidence Report (CCR) for the Village of Arlington on June 11, 2007. The CCR was reviewed for the required content. Based on our review, the Village of Arlington water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following violations were noted:

1. Include Total Chlorine residual levels in the Table of Detected Contaminants. (These levels can be found on the Total Chlorine Residual Operating Report Form 5114 which is available at <http://www.epa.state.oh.us/ddagw/drinkforms.htm>.)
2. Include the definitions for MRDL and MRDLG in your report.

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers by no later than July 1, 2008. A copy of the CCR and the Certification Form must be submitted to the Northwest District Office at the above address by July 1<sup>st</sup> annually. Violations in future reports may result in enforcement action.

The CCR template and template guide are available at <http://www.epa.state.oh.us/ddagw>.

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419)373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Environmental Specialist II  
Division of Drinking and Ground Waters

/cs

pc: Rick Monday, Superintendent of Water  
Hancock County Health Department  
~~DDAGW, NWDO File~~