



State of Ohio Environmental Protection Agency

Northwe

OH3200512

MT BLANCHARD, VILLAGE OF

5/26/2010

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 5



* 0 H 3 2 0 0 5 1 2 5 2 6 2 0 1 0 N O V *

JR
JR
JR

Re: Hancock County
Village of Mt. Blanchard
Community Water System
PWS ID# OH3200512
STU 1 ID# 3254800
STU 2 ID# 3260378

May 26, 2010

Mr. Paul Ritzler, Village Administrator
Village of Mt. Blanchard
105 East Clay Street
P. O. Box 333
Mt. Blanchard, Ohio 45867

RE: Notice of Violation – Quarterly Operating Report

Dear Mr. Ritzler:

The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Total Chlorine Residual Quarterly Operating Report (EPA 5114, revised April 2004) (QOR) for the January to March 2010 Quarter was received late on April 15, 2010.

Disinfection residual measurements are required to be taken for total chlorine according to Ohio Administrative Code (OAC) Rule 3745-81-70(E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [i.e. The July - September calendar quarter should have been submitted to the district office no later than October 10th.] The operational report is to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

The Division of Drinking and Ground Waters has started a web-based monthly report reporting site called eDWR. It may be more convenient for you to submit the monthly reports using eDWR. More information regarding this can be obtained at <http://www.epa.ohio.gov/ddagw/reporting.aspx#edwr>.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Hancock County Health Department
DBAGW-NWDO-File

