



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Hardin County  
Hillcrest Estates Mobile Home Court  
Community Water System  
PWS ID#OH3301212

August 13, 2008

OH3301212 4 MHC ASSOCIATES LIMITED PARTNERSHIP 8/13/2008

Mr. Steve R. Vreel  
4-MHC Associates Limited Partnership  
1120 North Main Street  
Rochester, Michigan 48307



Subject: 2007 CCR

Ohio EPA received the 2007 Consumer Confidence Report (CCR) for the Hillcrest Estates Mobile Home Court Public Water System on July 2, 2008. The CCR was reviewed for the required content. Based on our review, the Hillcrest Estates Mobile Home Court Public Water System is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-02 for failure to comply with the CCR requirements. The following deficiency was noted:

1. The Table of Detected Contaminants (see enclosed Chemical SSR Summary):
  - a. Included the level found of Nitrates in 2006. Nitrates were not detected in 2007 and therefore nitrates should be removed from the table of detected contaminants.

In addition, note the reported level found for Haloacetic Acids (Total) of 1.8 ppb is less than the Reporting Limit of 6.0 ppb and therefore may be omitted.

Be sure to correct the violations as appropriate in your next CCR. The next Consumer Confidence Report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Northwest District Office at the above address. The CCR template and template guide are accessible on our website: [www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw).

If you have any questions, please contact me at 419-373-3042.

Sincerely,

Larry W. Moritz  
Division of Drinking and Ground Waters  
/csl

pc: Phil Epley, Operator  
Hardin County Health Department  
(DDAGW/NWDO)