



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Hardin County
McGuffey Village PWS
PWS ID#OH3300712
STU ID#3354889


May 28, 2010

OH3300712

MCGUFFEY, VILLAGE OF

5/28/2010

Mr. James Meyer
810 South Gilbert Street
P.O. Box 304
Ada, Ohio 45810



Dear Mr. Meyer:

The Plant-Distribution Monthly Operation Report (MOR) (EPA Form 5002) for the April 2010, reporting period failed to report the concentration of iron weekly.

OAC 3745-83-01 (G)(9)(b) requires a public water system, serving 250 or more persons and provides treatment to reduce iron, shall monitor for iron at least weekly. If iron was monitored for weekly but the laboratory analysis was not available at the time the report was completed, a comment stating such may be added to the report and an amended report filed upon receipt of the laboratory analysis. This matter should also be discussed with your laboratory to investigate a means to have the results available for you to report on time.

Failure to take action to address these violations may result in enforcement action being taken.

Questions may be directed to my attention by contacting me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us .

Sincerely,

Larry Moritz
Division of Drinking and Ground Waters

//lr

pc: Hardin County Health Department
[BDAGW-NWDO File -]

