



State of Ohio Envi

OH3300712

MCGUFFEY, VILLAGE OF

5/6/2010

Northwe:

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 35
ww



Re: Hardin County
McGuffey Village PWS
PWS ID#OH3300712

May 6, 2010

Mr. James Meyer
810 South Gilbert Street
P.O. Box 304
Ada, Ohio 45810

Dear Mr. Meyer:

The Plant – Distribution Monthly Operation Report (MOR) (EPA Form 5002) was received by Ohio EPA on April 14, 2010, and failed to report the concentration of iron weekly.

Ohio Administrative Code Rule 3745-83-01(I)(2) requires the operation report to be submitted to the district office no later than the tenth of the month following the month for which the report was prepared and also requires the report to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

OAC 3745-83-01 (G)(9)(b) requires a public water system, serving 250 or more persons and provides treatment to reduce iron, shall monitor for iron at least weekly.

In regards to the analysis for iron, if iron was monitored for weekly but the laboratory analysis was not available at the time the report was completed, a comment stating such may be added to the report and an amended report filed upon receipt of the laboratory analysis. This matter should also be discussed with your laboratory to investigate a means to have the results available for you to report on time.

Failure to take action to address these violations may result in enforcement action being taken.

Questions may be directed to my attention by contacting me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us.

Sincerely,

Larry Moritz
Division of Drinking and Ground Waters

//lr

pc: Hardin County Health Department
DDAGW-NWDO File