



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH3500112

DESHLER, VILLAGE OF

5/24/2011



Re: Henry County
Deshler Village
Community PWS
PWS ID# OH3500112
STU ID# 3554984

May 24, 2011

Mr. Dennis Bremer, President
Board of Public Affairs
101 East Main Street
Deshler, Ohio 43516

**Failure to report iron weekly at the plant tap with either a test kit or lab analysis
(community < or equal 250) NOV OAC 3745-83-01(F)(5)(a)(i)**

Dear Mr. Bremer:

In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There was one (1) week during the month in which no analysis was reported.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Henry County Health Department
@DAGW-NWDO File - (1)