



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH3500112

DESHLER, VILLAGE OF

4/28/2011



Re: Henry County
Deshler Village
Community PWS
PWS ID# OH3500112
STU ID# 3554984

April 28, 2011

Mr. Dennis Bremer, President
Board of Public Affairs
101 East Main Street
Deshler, Ohio 43516

Violation of the secondary standard for iron - NOV OAC 3745-82-02

Dear Mr. Bremer:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported Iron greater than three-tenths milligrams per liter (mg/l) on March 1, 2011.

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There was 1 week during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:


- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mr. Dennis Bremer, President
April 28, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Henry County Health Department
DDAGW=NWDO File