

Re: Henry County  
Hamler Village  
Community PWS  
PWS ID# OH3500312  
STU ID# 3554985

May 24, 2011

Mr. Ken Jackman  
500 East Hubbard Street  
P. O. Box 435  
Hamler, Ohio 43524

**Violation of the secondary standard for iron - NOV OAC 3745-82-02**

Dear Mr. Jackman:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported Iron greater than three-tenths milligrams per liter (mg/l ) on April 19, 2011.

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There was one (1) week during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:


- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mr. Ken Jackman  
May 24, 2011  
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read "C. Riddle", written in a cursive style.

Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lr

pc: Henry County Health Department  
C:\DDAGW-NWDO-File - 1