



State of Ohio Environmental Protection Agency

North

OH3500312

HAMLER, VILLAGE OF

5/26/2010

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (4



* 0 H 3 5 0 0 3 1 2 5 2 6 2 0 1 0 N O V *

ernor
ernor
ector

Re: Henry County
Hamler Village
Community Public Water System
PWS ID# OH3500312
STU ID# 3554985

May 26, 2010

Mr. Ken Jackman, President
Board of Public Affairs
Village of Hamler
500 East Hubbard Street
P. O. Box 435
Hamler, Ohio 43524

RE: Notice of Violation – Quarterly Operating Report

Dear Mr. Jackman:

The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Total Chlorine Residual Quarterly Operating Report (EPA 5114, revised April 2004) (QOR) for the January to March 2010 Quarter was received late on April 12, 2010.

Disinfection residual measurements are required to be taken for total chlorine according to Ohio Administrative Code (OAC) Rule 3745-81-70(E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [i.e. The July - September calendar quarter should have been submitted to the district office no later than October 10th.] The operational report is to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

The Division of Drinking and Ground Waters has started a web-based monthly report reporting site called eDWR. It may be more convenient for you to submit the monthly reports using eDWR. More information regarding this can be obtained at <http://www.epa.ohio.gov/ddagw/reporting.aspx#edwr>.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs
pc: Henry County Health Department
DBAGW-NWDO File
ec: Tim Phillips, Certified Operator