



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH3500711

HENRY CO REGIONAL W AND S DIST

9/29/2010



Re: Henry County
Village of McClure
Community Water System
PWS ID# OH3500711

September 29, 2010

Mr. Nick Rettig, Director
Henry County Water and Sewer District
1857 Oakwood Avenue
Napoleon, Ohio 43545

Dear Mr. Rettig:

Ohio EPA received the 2009 Consumer Confidence Report (CCR) for the Village of McClure on June 24, 2010. The CCR was reviewed for the required content. Based on our review, the Village of McClure water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following violation was noted:

1. Mandatory health effects language for the lead action level exceedance was not included in the 2009 CCR. "Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Henry County Regional Water and Sewer District exceeded the lead action level in 2009. Henry County Regional Water and Sewer District is taking the following steps to correct this exceedance and prevent future exceedances from occurring:..."

The next report for calendar year (2010) must be sent to your customers by no later than July 1, 2011. One copy of the CCR, along with a Certification Form, must be submitted to the Northwest District Office by July 1st annually. The Ohio EPA CCR template, the Instructions for the Ohio EPA CCR and the CCR Certification Form are available on our web page. Violations in future reports may result in further enforcement action.

If you have any questions, contact me at (419) 373-4118.

Sincerely,

Justin W. Bowerman
Division of Drinking and Ground Waters

/llr

pc: Chris Diem, Superintendent
Henry County Health Department
Central Office, DDAGW, IMS
DDAGW, NWDO File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov