



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Henry County  
Village of McClure  
Community Water System  
PWS ID# 3500711


September 11, 2008

Mr. Nate Light, President BPA  
Village of McClure  
145 Haley Street  
P.O. Box 340  
McClure, Ohio 43534-0340

OH3500711

HENRY CO REGIONAL W AND S DIST

9/11/2008



Dear Mr. Nate Light:

Ohio EPA received the 2007 Consumer Confidence Report (CCR) for the Village of McClure on June 30, 2008. The CCR was reviewed for the required content. Based on our review, the Village of McClure water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following violations were noted:

1. Required health language due to an exceedance of a Maximum Contaminant Level was not included for HAA5s.
2. Required health information that was required as a result of a Treatment Technique violation was not included in the report (contact time violation December 2007).
3. The Table of Detected Contaminants did not contain results for total organic carbon, copper and total chlorine.

The next report for calendar year (2008) must be sent to your customers by no later than July 1, 2009. One copy of the CCR, along with a Certification Form, must be submitted to the Northwest District Office by July 1<sup>st</sup> annually. The Ohio EPA CCR template, the Instructions for the Ohio EPA CCR and the CCR Certification Form are available on our web page at [www.epa.state.oh.us/ddagw/ccr.html](http://www.epa.state.oh.us/ddagw/ccr.html). Violations in future reports may result in further enforcement action.

If you have any questions, contact me at (419)373-4118.

Sincerely,

Justin W. Bowerman  
Division of Drinking and Ground Waters

/lb

Enclosure (CCR)

pc: Chris Diem, Superintendent (w/ enclosure)  
Henry County Health Department  
Central Office, DDAGW, IMS

DDAGW, NWDO File