



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Henry County
Village of McClure
Community Water System
PWS ID# 3500711


September 28, 2007

OH3500711

HENRY CO REGIONAL W AND S DIST

9/28/2007

Mr. Nate Light, President BPA
Village of McClure
145 Haley Street
P.O. Box 340
McClure, Ohio 43534-0340



Dear Mr. Nate Light:

Ohio EPA received the 2006 Consumer Confidence Report (CCR) for the Village of McClure on June 28, 2007. The CCR was reviewed for the required content. Based on our review, the Village of McClure water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following violations were noted:

1. Required health language due to an exceedance of a Maximum Contaminant Level was not included for HAA5s.
2. Required health information that was required as a result of Treatment Technique violations was not included in the report.
3. The Table of Detected Contaminants did not contain results for total organic carbon, copper and total chlorine.
4. The Table of Detected Contaminants contained incorrect information. The sample year reported in the table was incorrect.

The next report for calendar year 2007 must be sent to your customers by no later than July 1, 2008. One copy of the CCR, along with a Certification Form, must be submitted to the Northwest District Office by July 1st annually. The Ohio EPA CCR template, the Instructions for the Ohio EPA CCR and the CCR Certification Form are available on our web page at www.epa.state.oh.us/ddagw/ccr.html Check our web-site annually, before preparing your CCR for the latest CCR template and instructions. Violations in future reports may result in further enforcement action.

Mr. Nate Light, President, EPA
September 28, 2007
Page 2

If you have any questions, contact me at (419) 373-4118.

Sincerely,



Justin W. Bowerman
Division of Drinking and Ground Waters

/llr

pc: Chris Diem, Superintendent
Henry County Health Department
Central Office, DDAGW, IMS
CDDAGW;NWDO File