



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH3500811

NAPOLEON, CITY OF

10/18/2010



* 0 H 3 5 0 0 8 1 1 1 0 1 8 2 0 1 0 N O V *

RE: Henry County
City of Napoleon
Community Water System
PWS ID# 3500811

October 18, 2010

Mr. Jon Bisher
City Manager
PO Box 151
Napoleon, Ohio 43545

Dear Mr. Bisher:

Review of the Fluoride Adjustment Report (EPA 5011) for August 2010 shows that the fluoride level fell below 0.8 mg/l for 5 days during the month. Take steps to keep the fluoride level between 0.8 and 1.3 mg/l.

Yours truly,

Debbie Ko
Division of Drinking and Ground Waters

/lb

Pc: Scott Hoover, Superintendent
Henry County Health Department

~~DDAGW, NWD, OI File~~

Colleen A. Wulf, RDH, MPH, ODH Bureau of Oral Health Services