



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Henry County
City of Napoleon
Community Water System
PWS ID# 3500811

January 29, 2009

OH3500811

NAPOLEON, CITY OF

1/29/2009

Mr. Roger Noblit
City of Napoleon
255 West Riverview Avenue
Napoleon, Ohio 43545



Dear Mr. Noblit:

Review of the Fluoride Adjustment Report (EPA 5011) for December 2008 shows that the fluoride level fell below 0.8 mg/l for ten (10) days during the month. Take steps to keep the fluoride level between 0.8 and 1.3 mg/l.

Yours truly,

Debbie Ko
Division of Drinking and Ground Waters

/cs

pc: Henry County Health Department
{DDAGW, NWDO File}