



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Huron County
Northern Ohio Rural Water
-Main District-
Community Water System
PWS ID #3902403

October 11, 2007

Mr. Bryan S. Puder
Distribution Superintendent
P.O. Box 96
Collins, Ohio 44826-0096

OH3902403

NORTHERN OHIO RURAL WATER

10/11/2007



SUBJECT: CCR VIOLATIONS

Dear Mr. Puder:

The Ohio EPA - Northwest District Office (NWDO) received the 2006 Consumer Confidence Report (CCR) for the Northern Ohio Rural Water (NORW) - Main District on July 9, 2007. The CCR was reviewed for the required content. Based on our review, the NORW - Main District public water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements, the following minor violations were noted:

1. **Total Chlorine residual levels were not included in the table.** (These levels can be found on your Total Chlorine Residual Quarterly Operating Report form EPA 5114. You can refer to our website for information regarding Total Chlorine residual reporting at: <http://www.epa.state.oh.us/ddagw/drinkforms.htm>).
2. **The key terms MRDL & MRDLG were not defined.** These two key terms are associated with Total Chlorine residual levels.


Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers by no later than July 1, 2008. A copy of the CCR along with a Certification Form must be submitted to NWDO at the above (letter head) address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website: www.epa.state.oh.us/ddagw

Mr. Bryan S. Puder
October 11, 2007
Page 2

If you have any questions, then please contact me directly at (419) 373-3088 or on the web at jack.schwartz@epa.state.oh.us.

Sincerely,



John A. (Jack) Schwartz
Environmental Specialist II
Public Drinking Water Unit
Division of Drinking and Ground Waters

/csj

cc: Huron County Health Department
DDAGW, NWDO Correspondence File

ec: Ellen Gerber, Manager, DDAGW, NWDO
Linda Benham, Supervisor, DDAGW, NWDO

(Minor Violation Type 72 2/6/06)