

Ohio


Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH3901511

WILLARD, CITY OF

2/15/2011



Re: Huron County
City of Willard
Community
PWS OH3901511

February 15, 2011

Mr. Brian Humphress
City Manager
City of Willard
631 South Myrtle Avenue
P. O. BOX 367
Willard, Ohio 44890-1549

Subject: Fluoride Violations - January 2011

Dear Mr. Humphress:

According to the Water Plant/Distribution System Monthly Operating Report, the public water system failed to maintain the fluoride concentration on four days during January 2011, at least 0.8 mg/L at the entry point into distribution system in violation of RC §§6109.20.

If the public water system fails to correct its violations, then the director may enforce the safe drinking water regulations to attain compliance. An enforcement action may include civil penalties of not more than \$25,000 per day per violation in accordance with RC §§6109.33, or administrative penalties in accordance with rule 3745-81-04.

If you have any questions regarding this letter, or any other matter involving your water system, you may contact me at (419)373-3048, or email [Ralph.Baker@epa.state.oh.us].

Sincerely,

Ralph J. Baker
Engineer
Division of Drinking and Ground Waters

/llr

pc: DDAGW, NWDO
Robert Niedermier, City of Willard
Eric Cherry, Huron County Health District

ec: Ralph Baker, DDAGW, NWDO
Paul Brock, DDAGW, NWDO
Linda Benham, DDAGW, NWDO
Ellen Gerber, DDAGW, NWDO