


**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korfeski, Director

OH4801012

GRAND VIEW LLC

1/5/2011



Re: Lucas County
Whispering Winds MHC
Community Water System
PWS ID# OH4801012

January 5, 2011

Ms. Cindy Stein
Whispering Winds Mobile Home Community
3203 West Lincolnshire Boulevard
Toledo, Ohio 43606

Dear Ms. Stein:


Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your October and November 2010 operational reports indicates that free chlorine residuals were below this level a total of 26 days in October and 30 days in November 2010.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly


Curtis A. Eldridge
Environmental Specialist 2
Division of Drinking and Ground Waters

/cs

pc: Lucas County Health Department
DDAGW/NWDDO.File

ec: Susan Baughman, Enforcement, DDAGW, CO