



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH4801012

GRAND VIEW LLC

11/22/2010



* 0 H 4 8 0 1 0 1 2 1 1 2 2 2 0 1 0 N O V *

Re: Lucas County
Whispering Winds Mobile Home Community
Community Water System
PWS ID# OH4801012

November 22, 2010

Ms. Cindy Stein
Whispering Winds Mobile Home Community
3203 West Lincolnshire Boulevard
Toledo, Ohio 43606

Dear Ms. Stein:

Ohio Administrative Code (OAC), Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your September 2010 operational report indicates that free chlorine residuals were below this level a total of 30 days.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with OAC Rule 3745-83-01.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly,

Curtis A. Eldridge
Environmental Specialist 2
Division of Drinking and Ground Water

/cs

pc: Lucas County Health Department
DDAGW, NWDO File