



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Marion County  
La Rue Village PWS  
Community Water System  
PWS ID#OH5100312

June 17, 2008

Mr. Tom Tucker, President  
Board of Public Affairs  
Village of La Rue  
P. O. Box 33  
La Rue, Ohio 43332

OH5100312

LA RUE, VILLAGE OF

6/17/2008



**Subject: 2007 CCR**

Dear Mr. Tucker:

Ohio EPA received the 2007 Consumer Confidence Report (CCR) for the La Rue Village PWS on June 13, 2008. The CCR was reviewed for the required content. Based on our review, the La Rue Village PWS is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-02 for the following omissions:

1. Definition of Maximum Residual Disinfectant Level Goal (MRDLG) was omitted.
2. In the Table of Detected Contaminants, MRDLG shall be reported for the contaminant of Total Chlorine.
3. The table of detected contaminants omitted the following detected contaminants identified in a sample collected from the entry point:
  - a. Bromodichloromethane 3.4 ug/l Sample date: 09/15/06
  - b. Bromoform 0.8 ug/l Sample date: 09/15/06
  - c. Chlorodibromomethane 2.5 ug/l Sample date: 09/15/06
  - d. Chloroform 3.2 ug/l Sample date: 09/15/06

Additional notes: The source water information did not include information regarding ongoing activity to address deficiencies associated with the existing wellfield or the addition of chemicals for the purpose of corrosion control.

Be sure to correct the violations as appropriate in your next CCR. The next Consumer Confidence Report for calendar year 2008 must be sent to your customers by no later than July 1, 2009.

Mr. Tom Tucker, President  
June 17, 2008  
Page 2

A copy of the CCR along with a Certification Form must be submitted to the Northwest District Office at the above address. The CCR template and template guide are accessible on our website: [www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw).

If you have any questions, please contact me at 419-373-3042.

Sincerely,



Larry W. Moritz  
Division of Drinking and Ground Waters

/llr

pc: Mark Hardin, Water Superintendent  
Marion County Health Department  
(DDAGW/NWDO)