



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

~ Jan. 2, 2009


Re: Marion County
Oakridge Estates, LLC
Community Water System
PWS ID # OH 5100212

Mr. Bryan Lawrence
1113 North Market Street
Galion, Ohio 44833

OH5100212

OAKRIDGE ESTATES, L.L.C.

1/2/2009



Dear Mr. Lawrence:

Ohio Administrative Code, (OAC) Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Review of your February 2009, operational report indicates that free/combined chlorine residuals were below this level thirteen days during the month. Action shall be taken to maintain chlorine residuals in conformance with OAC Rule 3745-83-01.

Sincerely,

Larry Moritz
Division of Drinking and Ground Waters

/llr

pc: McGhee's Technical Water Services
Marion County Health Department
cDDAGW, NWDO File