



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Marion County  
Oakridge Estates LLC  
Community Water System  
PWS ID No: OH5100212

October 3, 2007

OH5100212

OAKRIDGE ESTATES, L.L.C.

10/3/2007

Bryan and Mary Lawrence  
1113 North Market Street  
Galion, Ohio 44833



Subject: Review of Plant - Distribution MOR Reporting Month of August 2007

Dear Bryan and Mary Lawrence:

Ohio Administrative Code, Rule 3745-83-01 (C) requires each community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Review of your August 2007, operational report indicates the free/combined residuals were below this level eight (8) days during the month. Within 14 days, provide a written report of action being taken to correct this deficiency.

Should you have questions, please contact me at 419-373-3042.

Sincerely,

Larry Moritz  
Division of Drinking and Ground Waters

/llr

pc: Marion County Health Department  
Lonnie E McGhee Jr., President, MTWSi  
DDAGW/NWDO File