



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Mercer County
Club Island Association
Community Water System
PWS ID #5402012

August 25, 2009

OH5402012

CLUB ISLAND ASSOCIATION

8/25/2009

Mr. Craig Riesen, Operator
Club Island Association PWS
54125 Club Island Road
Celina, Ohio 45822



SUBJECT: 2008 Consumer Confidence Report (CCR) Violations

Dear Mr. Riesen:

The Ohio EPA-Northwest District Office (NWDO) received the 2008 CCR for the Club Island Association public water system (PWS) on June 26, 2009. The CCR was reviewed for the required content. Based on our review, the Club Island Association PWS is in violation of the Ohio Administrative Code (OAC) rules 3745-96-01 through 04 for failure to comply with CCR requirements, the following violations were noted:

1. The 'Table of Detected Contaminants' was included but the inorganic contaminant lead data presented was incorrect. The correct data would be that data collected from the year 2008. Correspondingly, the residual contaminant total chlorine data should also have been the most recent data which was collected in 2008.
2. Required health information that was required as a result of a lead action level (AL) exceedance was not included in the report. The following mandatory health effects language was to have been included verbatim:

"Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure."




Mr. Craig Riesen, Operator
August 25, 2009
Page 2

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2009 must be sent to your customers by no later than July 1, 2010. A copy of the CCR along with a Certification Form must be submitted to NWDO at the above address. Violations in future reports may result in further enforcement action.

The CCR Template Instruction Guide and Template are accessible via the internet on the Ohio EPA website at www.epa.state.oh.us/ddagw/ccr.html.

If you have any questions, then please contact me directly by telephone at (419) 373-3088 or via the internet at jack.schwartz@epa.state.oh.us.

Sincerely,



John A. (Jack) Schwartz
Environmental Specialist 2
Public Drinking Water Unit
Division of Drinking and Ground Waters

JAS/lr

pc: Ms. Kari Purtee, President
Mercer County Health Department
{DDAGW, NWDO Correspondence File}

ec: Linda Benham, Environmental Supervisor, DDAGW, NWDO
JoAnn Sabo, DOCC, DDAGW, NWDO