



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Ottawa County  
Allen Park MHP  
Community Water System  
PWS ID. #: 6204112


November 1, 2007

OH6204112

ALLEN PARK MOBILE COURT

11/1/2007

Mr. Dennis B. Brophy  
Pacific NW Property Management  
15685 SW 116<sup>th</sup>, # 109  
King City, Oregon 97224 - 2695



Dear Mr. Brophy:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for September 2007. A report was not received for the month of August 2007.

**Free and combined chlorine residuals** are required to be conducted at the **plant tap and in the distribution system daily (seven days per week)** according to Ohio Administrative Code (OAC) Rule 3745-83-01(G)(1) and (2). OAC Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., July's monthly operational report should be submitted to the district office no later than August 10<sup>th</sup>]. Effective October 1, 2006 the facility is required to **monitor for hardness at least monthly** at each entry point using a state certified laboratory in accordance with OAC Rule 3745-83-01(G)(8)(a).

**The owner / operator of Allen Park Mobile Court is in violation of OAC Rule 3745-83-01(I) for not submitting the August 2007 MOR, OAC Rule 3745-83-01(G)(1) for not monitoring for chlorine daily at the plant tap and in the distribution, and OAC Rule 3745-83-01(G)(8)(a) for not taking a Hardness sample in the month of August 2007.**

In addition, Allen Park Mobile Court is classified as a Class A public water system in accordance with OAC Rule 3745-7-03(B)(3) and is required to have a Class A operator of record. Ensure that Allen Park Mobile Court has or obtains a Class A operator. The operator of record must ensure that the system is functioning appropriately and must review and sign the reports. The operator-of-record must include his certification number along with the signature. If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/csl

c: Bill Wolfe, Park Manager  
Toni Buchanan, IMS, DDAGW, CO  
Ottawa County Health Department  
DDAGW, NWDO File