OhioEPA

State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Ottawa County
Allen Park MHP
Community Water System
PWS ID. #: 6204112

February 22, 2007

OH6204112 ALLEN PARK MOBILE COURT 2/22/2007

Mr. Dennis B. Brophy
Pacific NW Property Management
15685 SW 116th, # 109
King City, Oregon 97224 - 2695

OH6204112222200 7NOV

Dear Mr. Brophy:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the month of January 2007.

Free and combined chlorine residuals are required to be conducted at the **plant tap and in the distribution system daily (seven days per week)** according to OAC Rule 3745-83-01(G)(1) and (2). Ohio Administrative Code (OAC) Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., November's monthly operational report should be submitted to the district office no later than December 10th]. Effective October 1, 2006 the facility was required to **monitor for hardness at least monthly** at each entry point using a state certified laboratory in accordance with OAC Rule 3745-83-01(G)(8)(a).

The owner / operator of Allen Park Mobile Court is in violation of OAC Rule 3745-83-01(G). The aforementioned report must be submitted (EPA 5002) with all required sampling information.

In addition, Allen Park Mobile Court is classified as a Class A public water system in accordance with OAC Rule 3745-7-03(B)(3) and is required to have a Class A operator of record physically present at the public water system for at a minimum of 2 days per week for 1 hour per week in accordance with OAC Rule 3745-7-03(C)(1). Ensure that Allen Park Mobile Court has or obtains a Class A operator. Free training and certification is currently being offered in the state of Ohio. Current information on this training can be obtained at http://oepa.360water.com/

If a Class A operator is already on record at the facility please notify me of the individuals name and certification number. If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csl

pc: Larry Holland, Manager, Allen Park MHC
Toni Buchanan, IMS, DDAGW, CO
Ottawa County Health Department
DDAGW, NWDO File