



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, Ohio 43402

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Laura H. Powell, Acting Director

RE: Ottawa County
Allen Park MHP
Community Water System
PWS ID # 6204112


January 31, 2007

OH6204112

ALLEN PARK MOBILE COURT

1/31/2007

Mr. Dennis B. Brophy
Pacific NW Property Management
15685 SW 116th, # 109
King City, Oregon 97224 - 2695



Dear Mr. Brophy:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Reports (EPA 5002) (MOR) were received for your public water system for the months of February to December 2006 on January 11, 2007.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) and hardness must be monitored monthly at a state certified lab according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., December's monthly operational report should be submitted to the district office no later than January 10th].

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Reports (EPA 5114) (QOR) were received for the first, second, third, and fourth calendar quarters of 2006 on January 11, 2007.

Disinfection residual measurements are required to be taken for **total** chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [e.g., The fourth calendar quarter (October - December) should be submitted to the district office no later than January 10th.]

Mr. Dennis B. Brophy
January 31, 2007
Page 2

The owner / operator of Allen Park Mobile Court is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I), and OAC Rule 3745-81-70(E).

Free and combined chlorine samples must be taken and recorded daily (seven days per week) and hardness must be sampled and analyzed at a state certified laboratory on a monthly basis. Plant production must continue to be reported daily. The above data must be submitted to Ohio EPA by the 10th of the month following the reported data.

A copy of EPA form 5114, EPA form 5002 and instructions for completion are attached. Please contact me at (419) 373-3101 to discuss the above violations and to determine actions that must be taken to obtain compliance.

Sincerely,



Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csi

pc: Larry Holland, Manager, Allen Park MHC
Toni Buchanan, IMS, DDAGW, CO
Ottawa County Health Department
(DDAGW, NWDO File)